



	HEIGHT OF SUPPORTED BRICK ABOVE ANGLE	
	10'-0" (3050mm)	20'-0" (6100mm)
ANGLE SIZE	L4" x 4"x 1/4" (L102 x 102 x 6.35)	L4" x 4"x 1/4" (L102 x 102 x 6.35)
ANCHOR SIZE	1/2" DIA. (12.5mm DIA.)	1/2" DIA. (12.5mm DIA.)
ANCHOR SPACING	24" (610mm)	16" (406mm)

NOTES:

- 1 ASSUMES BRICK INSTALLATION IN ACCORDANCE WITH APPLICABLE CODES.
- 2 MIN. STEEL $F_y=43.5$ ksi (300 MPa) YIELD STRENGTH FOR ANGLES
- 3 ANGLES AND BOLTS TO BE GALVANIZED OR STAINLESS STEEL TO MEET THE REQUIREMENT OF TABLE 5.1 OF A370-04 (CONNECTIONS FOR MASONRY, OR EQUIVALENT STANDARD)

DISCLAIMER NOTICE:
SPECIFIC INFORMATION
REQUIRED FOR COMPLIANCE
WITH LOCAL CODES IS THE
RESPONSIBILITY OF THE
DESIGNER



NUDURA
INTEGRATED BUILDING TECHNOLOGY
Building Value.

NUDURA FORM UNIT
BRICK SHELF ANGLE
BACK OF ANGLE FLUSH
WITH E.P.S. EXTERIOR
(MULTI-STORY APPLICATION)

REV. NO.
003 TV

REV. DATE:
APR 2007

DRAWN BY
J.N. / N.L.

DWG NO.

A6B03

SCALE:

1 1/2"=1'-0"