



Notes: Calculated for Passive House calculations only, not to be used for UK Building Regs & SAP

 Ψ and *f* are only valid for the detail drawn and described above. 1.

2. The Ψ and f quoted are considered valid for U-value(s) Wall<= 0.185 Roof>= 0.11 W/m².K, (allowance of +/- 20%, following the present guidance from B. Anderson, BRE, correspondence dated 24/02/2012, for the UK market). The use of different claddings may affect the U-value slightly, but will have no material impact on the calculated values used here, in this case.

- 3. In dwellings, UK regulations stipulate that a temperature factor f that is >0.75 would avoid the risk of mould growth. For other nations, jurisdictions and climates, please consult the local building regulations that apply for avoiding mould and condensation. (For example, typical requirements may be: Netherlands: 0.65; Switzerland: 0.75; Belgium: 0.7; Germany: 0.7; Finland: 0.87. French, German and other standards often do not indicate a single number for acceptable risk, but are dependent on circumstances.) 4.
 - Calculations have been performed in accordance with:
 - EN ISO 10211_2007 (British Standards) .
 - IP 1/06 & BR497 (BRE Press)

and with reference to the following publications:

- EN ISO 6946 (British Standards)
- BR443 (BRE Press)