


FJ240

Spanatherm Cavity Barrier

19-02-2025 / V 1

Description

FJ240 Spanatherm is dense rock mineral fibre board Class A1 core with an aluminium foil applied to two faces.



Features and Benefits

- Up to 2 hours integrity and 90 minutes insulation - Tested to BS 476 20-22
- Dry fit system
- Easy to install
- Vapour, smoke and acoustic seal
- Can be installed prior to the application of the cladding system

Usage Purpose

FJ240 Spanatherm is a strong pre-engineered rock fibre movement-joint fire seal, vertical fibre orientation, that allows movement accommodation at the same time as providing fire integrity, insulation and an effective smoke seal.

FJ240 Spanatherm is a cost effective and efficient product for compartment reinstatement at edge of slab, or vertically, to external façade of the structure.

Suitable for both static or movement joints.

Packaging

Supplied individually
Dimensions 1200mm x 600mm x 100mm

Storage

Store in dry conditions between -10°C and +70°C. Do not store directly on concrete floors.

FJ240

Spanatherm Cavity Barrier

Technical Characteristics

Dimensions	1200 x 600 x 100 mm thick slabs.
Composition	Compressed rock fibre, foil faced on both sides
Application Temperature	Up to +60°C
Storage	Store in dry shaded conditions between -10°C and +70°C. Do not store directly on concrete floors.
Shelf Life	Unlimited when stored as recommended.

Substrate Preparation

All surfaces must be clean and sound, free from dirt, grease and other contamination.

Necessary Tools

Appropriate cutting tool (mineral wool knife, hand saw, etc...)

Protective Equipment

Ensure all recommended protective equipment is worn during handling & use of this product. For full recommendation, refer to safety data sheet.

Application

Measure the gap width of the opening to be sealed.

Cut FJ240 into strips lengthways to the width of opening plus suitable movement allowance (accommodating a maximum size) plus 5 to 10mm above maximum gap size expected.

Under compression, install the cut length of FJ240. Where the opening width exceeds 50mm or the cladding system is non-fire rated, either edge clips or V-lock spikes will be required to provide sufficient support in relation to gap width. The clip is fixed into the slab side edge of FJ240 and mechanically fixed either to top of floor slab (Z-clip), vertical edge of floor slab (V-lock spike) or L-bracket. 3 fixings are required per 1200mm, minimum 2 per cut piece (maximum 600 mm else 3 fixings required), at maximum 400 mm (200mm/600 mm/1000 mm from right hand edge). See Fixing Information paragraph below.

Butt joint additional lengths of FJ240 to create the seal required.

All joints to all substrates, including board to board joints, should be smoke sealed using a minimum 75mm 30 micron foil tape. If area is exposed to high humidity or if moisture is expected, we would recommend a 100mm 50 micron specialist water resistant tape.

Fixing Information

- Z clips are for vertical and horizontal use, in gaps up to 250mm.
- V-lock spikes are for vertical and horizontal use, in gaps 250-400 mm.
- L-brackets are for vertical use only, in gaps 50-200mm.
- All brackets must be cut to permit movement tolerances, and must pass through 75% of the FJ240 width.

FJ240

Spanatherm Cavity Barrier

Please Note

Maximum tested opening is 400 mm width.

Movement capability is 7.5%.

Can only be cut along the product 1200mm length.

The Integrity and Insulation rating of FJ240 may be limited to the capability of the surrounding substrates.

Maintenance

No maintenance required after installation. Routine inspection recommended to ensure no damage to the system.

Guarantee / Warranty

Tremco CPG UK Limited products are manufactured to rigid standards of quality. Any product which has been applied (a) in accordance with Tremco CPG UK Limited written instructions and (b) in any application recommended by Tremco CPG UK Limited, but which is proved to be defective, will be replaced free of charge.

No liability can be accepted for the information provided in this leaflet although it is published in good faith and believed to be correct.

Tremco CPG UK Limited reserves the right to alter product specifications without prior notice, in line with Company policy of continuous development and improvement.

It is a requirement of the installer to ensure suitability and compatibility of all elements before installation commences and that compliance can be achieved as required.

Health And Safety Precautions

Safety data sheet must be read and understood before use.

Technical Service

Tremco CPG UK Limited has a team of experienced Technical Sales Representatives who provide assistance in the selection and specification of products. For more detailed information, service and advice, please call Customer Services on 01942 251400



Tremco CPG UK Limited
Coupland Road, Hindley
Green
Wigan, WN2 4HT
United Kingdom
+44 (0)1942 251400
hello@tremcocpg.com